

Milcrofton Utility District Water Quality Report for 2019

Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 57 contaminants that may be in drinking water. The EPA and the State require us to test our water and report findings on a regular basis to ensure safety and quality standards are met. As you'll see in the chart on the back, we continually strive to maintain and improve the water you drink because our families drink it, too.

What is the source of my water?

Your water, which is surface water, comes from Harpeth Valley Utilities District. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Milcrofton Utility District sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact TDEC at 1-888-891-8332 to obtain copies of specific assessments.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Mike Jones (615) 794-5947.

How can I get involved?

Our Water Board meets on the fourth Wednesday of each month at 9:00 a.m. at the utility office. Board meetings are open to the public. In order to be heard by the Board, placement on the agenda for the meeting is required. The Commissioners of Milcrofton Utility District serve four year terms. Vacancies on the Board of Commissioners are filled by appointment by the Williamson County Mayor from a list of three nominees certified by the Board of Commissioners to the Williamson County Mayor to fill a vacancy. Decisions by the Board of Commissioners on customer complaints brought before the Board of Commissioners under the District's customer complaint policy may be reviewed by the Utility Management Review Board of the Tennessee Department of Environment and Conservation pursuant to Section 7-82-702(7) of Tennessee Code Annotated.

Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. Milcrofton Utility District's water processes are designed to reduce any such substances to levels well below any health concern. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about not only their drinking water, but food preparation, personal hygiene, and precautions regarding the handling of infants and pets. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Milcrofton Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to (615) 794-5947.

Water Quality Data

What does this chart mean?

- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL** - Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG** - Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Below Detection Level (BDL)** - laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- **Non-Detects (ND)** - laboratory analysis indicates that the contaminant is not present.
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **TT** - Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.
- **Turbidity** – Turbidity does not present any risk to your health. Harpeth Valley Utility Districts monitors turbidity a measure of the cloudiness of water, because it is a good indicator that the filtration system is functioning properly.
- **RTCR** – Revised Total Coliform Rule. This rule went into effect April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.

THE DATA IN THIS TABLE IS FROM TESTING BETWEEN JANUARY 1, 2019 AND DECEMBER 31, 2019

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit of Measurement	MCLG	MCL	Likely Source of Contamination
Turbidity ¹	NO	.05 Avg.	0.03 - 0.82	2019	NTU	N/A	TT	Soil runoff
Total Organic Carbon (TOC) ²	NO	1.31 MAX	1.08 - 1.31	2019	PPM	N/A	TT	Naturally present in the environment.
Total Coliform Bacteria (RTCR)*	NO	0		30/Month		0	TT Trigger	Naturally present in the environment
Inorganic Contaminants	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit of Measurement	MCLG	MCL	Likely Source of Contamination
Chlorine	NO	1.42 Avg.	1.00 - 1.90	2019	PPM	4	4	Water additive used to control microbes
Fluoride	NO	0.44 Avg.	0.04 - 0.65	2019	PPM	4.0	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate	NO	0.45		11/12/19	PPM	10	10	Soil runoff from fertilizer
Sodium	NO	7.65		12/17/19	PPM	N/A	N/A	Erosion of natural deposits; used in water treatment
Volatile Contaminants	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit of Measurement	MCLG	MCL	Likely Source of Contamination
Total Trihalomethanes (TTHM)	NO	40.4	23 - 61	2019	PPB	N/A	80	By-product of drinking water chlorination
Total Haloacetic Acids (THAA)	NO	31.5	20 – 43	2019	PPB	N/A	60	By-product of drinking water disinfection.
Lead and Copper	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit of Measurement	MCLG	MCL	Likely Source of Contamination
Lead ³	NO	90 th % = ND		2017	PPB	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Copper ³	NO	90 th % = 0.173		2017	PPM	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Miscellaneous Compounds	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit of Measurement	MCLG	MCL	Likely Source of Contamination
Alkalinity	NO	69.0 Avg.	48 – 108	2019	PPM	N/A	N/A	The capacity of water to neutralize acids.
Hardness ⁴	NO	92 Avg.	70 – 122	2019	PPM	N/A	N/A	Erosion of natural deposits.

Unregulated Contaminants	Level Detected (PPB)	Range of Detections
Monochloroacetic Acid ⁵	3.84 Avg.	2.82 - 5.39
Monobromoacetic Acid ⁵	1.73 Avg.	1.25 - 3.03
Dichloroacetic Acid ⁵	12.31 Avg.	8.04 - 17.00
Trichloroacetic Acid ⁵	14.75 Avg.	10.80 - 19.20
Bromochloroacetic Acid ⁵	2.64 Avg.	1.91 - 3.39
Dibromoacetic Acid ⁵	0.373 Avg.	0.367 - 0.379
Bromodichloroacetic Acid ⁵	3.73 Avg.	2.94 - 4.54
Chlorodibromoacetic Acid ⁵	0.383 Avg.	0.320 - 0.415
Manganese ⁵	1.063 Avg.	0.826 – 1.300

¹We met the Treatment Technique requirement for Turbidity in 2019, 100% of monthly samples were below the turbidity limit of 0.3 NTU.

²We met the Treatment Technique requirements for Total Organic Carbon in 2019.

³During the most recent round of Lead and Copper testing, 0 out of 30 households sampled contained concentrations exceeding the action level.

⁴Equivalent to 5.4 grains per gallon of hardness.

⁵Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. For more information call the Safe Drinking Water Hotline at (800) 426-4791.